

Location:	Sample #:	Results	Re-Test	Location:	Sample#:	Results	Re-Test
Main Office Work Room	FL-001	2.4		Room 22 sink	FL-037	8.7	
Restroom Sink	FL-002	1.5		Restroom Washtree	FL-038	1.7	
Restroom Sink	FL-003	2.9		Corridor C202 Fountain	FL-039	<1.0	
Nurse's Sink	FL-004	6.1		Restroom 22C	FL-040	4.2	
Nurse's Bathrm Sink	FL-004A	3.8		Restroom-Men's	FL-040A	4.3	
Boy's Washtree	FL-005	1.8		Room 23 Sink	FL-041	6.8	
Faculty Restroom Sink	FL-006	3.2		Restroom 23A Washtree	FL-042	3.1	
Faculty Room	FL-06A	4.4		Room 24 Sink	FL-043	3.4	
Room 2 Sink	FL-007	5.9		Room 25 Sink	FL-044	3.0	
Room 3 Sink	FL-008	4.4		Room 26 Sink	FL-045	4.5	
Room 4A- Sink	FL-009	1.9		Conference Rm sink	FL-045A	5.2	
Room 4 -Sink	FL-010	3.7		Room 27 Sink	FL-046	4.5	
Restroom Sink	FL-011	1.6		Room 28 Sink	FL-047	4.2	
Restroom Sink	FL-012	1.6		Room 29 Sink	FL-048	4.0	
Room 5 Sink	FL-013	11.0		Room 30 Sink	FL-049	3.8	
Room 6 Sink	FL-014	7.7		Room 31 Sink	FL-050	4.7	
Room 7 Sink	FL-015	3.8		Room 32 Sink	FL-051	6.6	
Room 8 Sink	FL-016	7.0		Restroom 32A Washtree	FL-052	3.4	
Room 9 Sink	FL-017	5.5		Room 33 Sink	FL-053	6.3	
Room 10 Sink	FL-018	6.3		Room 34 Sink	FL-054	4.0	
Room 11 Bathroom	FL-019	2.0		Restroom 34A Washtree	FL-055	4.4	
Room 11 Sink	FL-020	4.8		Restroom Sink	FL-056	0.0	
Room 12 Bathroom	FL-021	12.0		Room 35 Sink	FL-057	6.0	
Room 12 Sink	FL-022	3.9		Room 36 Sink	FL-058	6.9	
Restroom Washtree	FL-023	2.9		Corridor C201 Fountain	FL-059	<1.0	
Room 13 Sink	FL-024	13.0					
Restroom Washtree	FL-025	1.7					
Room 14 sink	FL-026	25.0	3.5				
Room 14 sink	FL-26A	19.0	1.6				
Room 15 sink	FL-027	6.8					
Corridor C101 Fountain	FL-028	<1.0					
Library Office	FL-029	4.7					
Corridor C102 Fountain	FL-030	<1.0					
Kitchen Sink-Hand	FL-031	5.3					
Kitchen Sink	FL-031A	13.0					
Kitchen Sink	FL-032	17.0	6.8				
Kitchen Sink-Dishwashing	FL-032A	57.0	32.5				
Gym 106	FL-033	2.3					
Gym 107	FL-034	9.4					
Gym 107 B	FL-035	6.7					
Room 21 Sink	FL-036	6.0					