

Location:	Sample #:	Results	Re-Test
Main Office Work Room	FL-001	2.4	
Restroom Sink	FL-002	1.5	
Restroom Sink	FL-003	2.9	
Nurse's Sink	FL-004	6.1	
Nurse's Bathrm Sink	FL-004A	3.8	
Boy's Washtree	FL-005	1.8	
Faculty Restroom Sink	FL-006	3.2	
Faculty Room	FL-06A	4.4	
Room 2 Sink	FL-007	5.9	
Room 3 Sink	FL-008	4.4	
Room 4A- Sink	FL-009	1.9	
Room 4 -Sink	FL-010	3.7	
Restroom Sink	FL-011	1.6	
Restroom Sink	FL-012	1.6	
Room 5 Sink	FL-013	11.0	
Room 6 Sink	FL-014	7.7	
Room 7 Sink	FL-015	3.8	
Room 8 Sink	FL-016	7.0	
Room 9 Sink	FL-017	5.5	
Room 10 Sink	FL-018	6.3	
Room 11 Bathroom	FL-019	2.0	
Room 11 Sink	FL-020	4.8	
Room 12 Bathroom	FL-021	12.0	
Room 12 Sink	FL-022	3.9	
Restroom Washtree	FL-023	2.9	
Room 13 Sink	FL-024	13.0	
Restroom Washtree	FL-025	1.7	
Room 14 sink	FL-026	25.0	3.5
Room 14 sink	FL-26A	19.0	1.6
Room 15 sink	FL-027	6.8	
Corridor C101 Fountain	FL-028	<1.0	
Library Office	FL-029	4.7	
Corridor C102 Fountain	FL-030	<1.0	
Kitchen Sink-Hand	FL-031	5.3	
Kitchen Sink	FL-031A	13.0	
Kitchen Sink	FL-032	17.0	6.8
Kitchen Sink-Dishwashing	FL-032A	57.0	5.8
Gym 106	FL-033	2.3	
Gym 107	FL-034	9.4	
Gym 107 B	FL-035	6.7	

Room 21 Sink	FL-036	6.0	
--------------	--------	-----	--

--	--	--	--