

Lead in Water Testing Results:**District Buildings****12/3/25**

EPA Limit: 15 mcg/L (micrograms per liter)

NYS Limit: >5 mcg/L

Outlets Exceeding the 5 mcg/L Limit:

Charlton Heights:	Outlets Tested:	38
--------------------------	------------------------	-----------

Sample ID: **Location:** **Reading:**

CH-008	AB Connector	7.2
CH-032	D-1 Sink	5.4

FL Stevens:	Outlets Tested:	42
--------------------	------------------------	-----------

Sample ID: **Location:** **Reading:**

FL-027	Rm. 15 sink	5.3
FL-031	Kitchen dish sink	5.6
FL-045	Rm. 26A sink	7
FL-046	Rm. 27 sink	5.6

Pashley:	Outlets Tested:	47
-----------------	------------------------	-----------

Sample ID: **Location:** **Reading:**

PA-043	Kitchen Utility-Eye	5.3
--------	---------------------	-----

High School:	Outlets Tested:	42
---------------------	------------------------	-----------

Sample ID: **Location:** **Reading:**

HS-04	Kitchen Dish Sink	15.3
HS-06	Kitchen Dish Sink	6.7

Middle School:	Outlets Tested:	33
-----------------------	------------------------	-----------

Sample ID: **Location:** **Reading:**

MS-155 2nd Fl. Stairs Fntr 14.8

