



December 02, 2025

Lauren Doherty
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Dear Lauren Doherty:

Enclosed are the analytical results for sample(s) received by the laboratory on November 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Lori Beyer".

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures

cc: Lauren Doherty, Intertek PSI



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70391830001	HS-01	Drinking Water	11/13/25 04:51	11/15/25 07:37
70391830002	HS-02	Drinking Water	11/13/25 04:53	11/15/25 07:37
70391830003	HS-03	Drinking Water	11/13/25 04:54	11/15/25 07:37
70391830004	HS-04	Drinking Water	11/13/25 04:55	11/15/25 07:37
70391830005	HS-05	Drinking Water	11/13/25 04:56	11/15/25 07:37
70391830006	HS-06	Drinking Water	11/13/25 04:56	11/15/25 07:37
70391830007	HS-07	Drinking Water	11/13/25 05:00	11/15/25 07:37
70391830008	HS-08	Drinking Water	11/13/25 05:02	11/15/25 07:37
70391830009	HS-09	Drinking Water	11/13/25 05:03	11/15/25 07:37
70391830010	HS-10	Drinking Water	11/13/25 05:06	11/15/25 07:37
70391830011	HS-11	Drinking Water	11/13/25 05:09	11/15/25 07:37
70391830012	HS-12	Drinking Water	11/13/25 05:10	11/15/25 07:37
70391830013	HS-13	Drinking Water	11/13/25 05:12	11/15/25 07:37
70391830014	HS-14	Drinking Water	11/13/25 05:14	11/15/25 07:37
70391830015	HS-15	Drinking Water	11/13/25 05:14	11/15/25 07:37
70391830016	HS-16	Drinking Water	11/13/25 05:17	11/15/25 07:37
70391830017	HS-17	Drinking Water	11/13/25 05:18	11/15/25 07:37
70391830018	HS-18	Drinking Water	11/13/25 05:24	11/15/25 07:37
70391830019	HS-19	Drinking Water	11/13/25 05:26	11/15/25 07:37
70391830020	HS-20	Drinking Water	11/13/25 05:27	11/15/25 07:37
70391830021	HS-21	Drinking Water	11/13/25 05:28	11/15/25 07:37
70391830022	HS-22	Drinking Water	11/13/25 05:32	11/15/25 07:37
70391830023	HS-23	Drinking Water	11/13/25 05:33	11/15/25 07:37
70391830024	HS-24	Drinking Water	11/13/25 05:36	11/15/25 07:37
70391830025	HS-25	Drinking Water	11/13/25 05:39	11/15/25 07:37
70391830026	HS-26	Drinking Water	11/13/25 05:42	11/15/25 07:37
70391830027	HS-27	Drinking Water	11/13/25 05:42	11/15/25 07:37
70391830028	HS-28	Drinking Water	11/13/25 05:50	11/15/25 07:37
70391830029	HS-29	Drinking Water	11/13/25 05:53	11/15/25 07:37
70391830030	HS-30	Drinking Water	11/13/25 05:55	11/15/25 07:37
70391830031	HS-31	Drinking Water	11/13/25 05:57	11/15/25 07:37
70391830032	HS-32	Drinking Water	11/13/25 05:58	11/15/25 07:37
70391830033	HS-33	Drinking Water	11/13/25 05:59	11/15/25 07:37
70391830034	HS-34	Drinking Water	11/13/25 06:01	11/15/25 07:37
70391830035	HS-35	Drinking Water	11/13/25 06:02	11/15/25 07:37
70391830036	HS-36	Drinking Water	11/13/25 06:03	11/15/25 07:37
70391830037	HS-37	Drinking Water	11/13/25 06:03	11/15/25 07:37

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70391830038	HS-38	Drinking Water	11/13/25 06:13	11/15/25 07:37
70391830039	HS-39	Drinking Water	11/13/25 06:18	11/15/25 07:37
70391830040	HS-40	Drinking Water	10/23/25 06:17	11/15/25 07:37
70391830041	HS-41	Drinking Water	10/23/25 06:18	11/15/25 07:37
70391830042	HS-42	Drinking Water	10/23/25 06:10	11/15/25 07:37

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70391830001	HS-01	EPA 200.8	JP2	1
70391830002	HS-02	EPA 200.8	JP2	1
70391830003	HS-03	EPA 200.8	JP2	1
70391830004	HS-04	EPA 200.8	JP2	1
70391830005	HS-05	EPA 200.8	JP2	1
70391830006	HS-06	EPA 200.8	JP2	1
70391830007	HS-07	EPA 200.8	JP2	1
70391830008	HS-08	EPA 200.8	JP2	1
70391830009	HS-09	EPA 200.8	JP2	1
70391830010	HS-10	EPA 200.8	JP2	1
70391830011	HS-11	EPA 200.8	JP2	1
70391830012	HS-12	EPA 200.8	JP2	1
70391830013	HS-13	EPA 200.8	JP2	1
70391830014	HS-14	EPA 200.8	JP2	1
70391830015	HS-15	EPA 200.8	JP2	1
70391830016	HS-16	EPA 200.8	JP2	1
70391830017	HS-17	EPA 200.8	JP2	1
70391830018	HS-18	EPA 200.8	JP2	1
70391830019	HS-19	EPA 200.8	JP2	1
70391830020	HS-20	EPA 200.8	JP2	1
70391830021	HS-21	EPA 200.8	JP2	1
70391830022	HS-22	EPA 200.8	JP2	1
70391830023	HS-23	EPA 200.8	JP2	1
70391830024	HS-24	EPA 200.8	JP2	1
70391830025	HS-25	EPA 200.8	JP2	1
70391830026	HS-26	EPA 200.8	JP2	1
70391830027	HS-27	EPA 200.8	JP2	1
70391830028	HS-28	EPA 200.8	JP2	1
70391830029	HS-29	EPA 200.8	JP2	1
70391830030	HS-30	EPA 200.8	JP2	1
70391830031	HS-31	EPA 200.8	JP2	1
70391830032	HS-32	EPA 200.8	JP2	1
70391830033	HS-33	EPA 200.8	JP2	1
70391830034	HS-34	EPA 200.8	JP2	1
70391830035	HS-35	EPA 200.8	JP2	1
70391830036	HS-36	EPA 200.8	JP2	1
70391830037	HS-37	EPA 200.8	JP2	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70391830038	HS-38	EPA 200.8	JP2	1
70391830039	HS-39	EPA 200.8	JP2	1
70391830040	HS-40	EPA 200.8	JP2	1
70391830041	HS-41	EPA 200.8	JP2	1
70391830042	HS-42	EPA 200.8	JP2	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-01		Lab ID: 70391830001		Collected: 11/13/25 04:51		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		12/01/25 18:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-02		Lab ID: 70391830002		Collected: 11/13/25 04:53		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		12/01/25 18:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-03		Lab ID: 70391830003		Collected: 11/13/25 04:54		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		12/01/25 18:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-04		Lab ID: 70391830004		Collected: 11/13/25 04:55		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	15.3	ug/L	1.0	1		12/01/25 18:26	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-05		Lab ID: 70391830005		Collected: 11/13/25 04:56		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		12/01/25 18:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-06		Lab ID: 70391830006		Collected: 11/13/25 04:56		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.7	ug/L	1.0	1		12/01/25 18:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-07		Lab ID: 70391830007		Collected: 11/13/25 05:00		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 18:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-08		Lab ID: 70391830008		Collected: 11/13/25 05:02		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 18:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-09		Lab ID: 70391830009		Collected: 11/13/25 05:03		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		12/01/25 18:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-10		Lab ID: 70391830010		Collected: 11/13/25 05:06		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 18:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-11		Lab ID: 70391830011	Collected: 11/13/25 05:09	Received: 11/15/25 07:37	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/01/25 18:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-12		Lab ID: 70391830012		Collected: 11/13/25 05:10		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		12/01/25 18:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-13		Lab ID: 70391830013		Collected: 11/13/25 05:12		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 18:42	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-14		Lab ID: 70391830014		Collected: 11/13/25 05:14		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 18:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-15		Lab ID: 70391830015		Collected: 11/13/25 05:14		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 18:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-16		Lab ID: 70391830016		Collected: 11/13/25 05:17		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		12/01/25 18:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-17		Lab ID: 70391830017		Collected: 11/13/25 05:18		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:00	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-18		Lab ID: 70391830018		Collected: 11/13/25 05:24		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.0	ug/L	1.0	1		12/01/25 19:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-19		Lab ID: 70391830019		Collected: 11/13/25 05:26		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-20		Lab ID: 70391830020	Collected: 11/13/25 05:27	Received: 11/15/25 07:37	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/01/25 19:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-21		Lab ID: 70391830021		Collected: 11/13/25 05:28		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-22		Lab ID: 70391830022	Collected: 11/13/25 05:32	Received: 11/15/25 07:37	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/01/25 19:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-23		Lab ID: 70391830023		Collected: 11/13/25 05:33		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-24		Lab ID: 70391830024		Collected: 11/13/25 05:36		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-25		Lab ID: 70391830025		Collected: 11/13/25 05:39		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-26		Lab ID: 70391830026		Collected: 11/13/25 05:42		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-27		Lab ID: 70391830027		Collected: 11/13/25 05:42		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-28		Lab ID: 70391830028		Collected: 11/13/25 05:50		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-29		Lab ID: 70391830029		Collected: 11/13/25 05:53		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-30		Lab ID: 70391830030		Collected: 11/13/25 05:55		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-31		Lab ID: 70391830031	Collected: 11/13/25 05:57	Received: 11/15/25 07:37	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/01/25 19:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-32		Lab ID: 70391830032		Collected: 11/13/25 05:58		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-33		Lab ID: 70391830033		Collected: 11/13/25 05:59		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:30	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-34		Lab ID: 70391830034	Collected: 11/13/25 06:01	Received: 11/15/25 07:37	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/01/25 19:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-35		Lab ID: 70391830035		Collected: 11/13/25 06:02		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:39	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-36		Lab ID: 70391830036		Collected: 11/13/25 06:03		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-37		Lab ID: 70391830037		Collected: 11/13/25 06:03		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-38		Lab ID: 70391830038		Collected: 11/13/25 06:13		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-39		Lab ID: 70391830039		Collected: 11/13/25 06:18		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/01/25 19:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-40		Lab ID: 70391830040		Collected: 10/23/25 06:17		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		12/01/25 19:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13
Pace Project No.: 70391830

Sample: HS-41		Lab ID: 70391830041		Collected: 10/23/25 06:18		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		12/01/25 19:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Sample: HS-42		Lab ID: 70391830042		Collected: 10/23/25 06:10		Received: 11/15/25 07:37		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		12/01/25 19:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

QC Batch:	430489	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70391830001, 70391830002, 70391830003, 70391830004, 70391830005, 70391830006, 70391830007, 70391830008, 70391830009, 70391830010, 70391830011, 70391830012, 70391830013		

METHOD BLANK:	2303233	Matrix:	Water
Associated Lab Samples:	70391830001, 70391830002, 70391830003, 70391830004, 70391830005, 70391830006, 70391830007, 70391830008, 70391830009, 70391830010, 70391830011, 70391830012, 70391830013		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/01/25 17:59	

LABORATORY CONTROL SAMPLE:	2303234					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.8	104	85-115	

MATRIX SPIKE SAMPLE:		2303236					
		70391829027	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	58.1	116	70-130	

MATRIX SPIKE SAMPLE:		2303238					
		70391829028	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	14.8	50	67.4	105	70-130	

SAMPLE DUPLICATE:	2303235					
Parameter	Units	70391829027 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	2303237					
Parameter	Units	70391829028 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	14.8	15.0	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

QC Batch:	430521	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70391830014, 70391830015, 70391830016, 70391830017, 70391830018, 70391830019, 70391830020, 70391830021, 70391830022, 70391830023, 70391830024, 70391830025, 70391830026, 70391830027, 70391830028, 70391830029, 70391830030, 70391830031, 70391830032, 70391830033		

METHOD BLANK:	2303525	Matrix:	Water
Associated Lab Samples:	70391830014, 70391830015, 70391830016, 70391830017, 70391830018, 70391830019, 70391830020, 70391830021, 70391830022, 70391830023, 70391830024, 70391830025, 70391830026, 70391830027, 70391830028, 70391830029, 70391830030, 70391830031, 70391830032, 70391830033		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/01/25 18:44	

LABORATORY CONTROL SAMPLE:	2303526					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE SAMPLE:		2303528					
		70391830014	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	55.8	112	70-130	

MATRIX SPIKE SAMPLE:		2303530					
		70391830015	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	52.4	105	70-130	

SAMPLE DUPLICATE:	2303527					
Parameter	Units	70391830014 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	2303529					
Parameter	Units	70391830015 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

QC Batch:	430523	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70391830034, 70391830035, 70391830036, 70391830037, 70391830038, 70391830039, 70391830040, 70391830041, 70391830042		

METHOD BLANK:	2303533	Matrix:	Water
Associated Lab Samples:	70391830034, 70391830035, 70391830036, 70391830037, 70391830038, 70391830039, 70391830040, 70391830041, 70391830042		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/01/25 19:31	

LABORATORY CONTROL SAMPLE:	2303534					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE SAMPLE:	2303536						
Parameter	Units	70391830034 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	59.2	118	70-130	

SAMPLE DUPLICATE: 2303535						
		70391830034	Dup		Max	
Parameter	Units	Result	Result	RPD	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BURNT HILLS HS 11/13

Pace Project No.: 70391830

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70391830001	HS-01	EPA 200.8	430489		
70391830002	HS-02	EPA 200.8	430489		
70391830003	HS-03	EPA 200.8	430489		
70391830004	HS-04	EPA 200.8	430489		
70391830005	HS-05	EPA 200.8	430489		
70391830006	HS-06	EPA 200.8	430489		
70391830007	HS-07	EPA 200.8	430489		
70391830008	HS-08	EPA 200.8	430489		
70391830009	HS-09	EPA 200.8	430489		
70391830010	HS-10	EPA 200.8	430489		
70391830011	HS-11	EPA 200.8	430489		
70391830012	HS-12	EPA 200.8	430489		
70391830013	HS-13	EPA 200.8	430489		
70391830014	HS-14	EPA 200.8	430521		
70391830015	HS-15	EPA 200.8	430521		
70391830016	HS-16	EPA 200.8	430521		
70391830017	HS-17	EPA 200.8	430521		
70391830018	HS-18	EPA 200.8	430521		
70391830019	HS-19	EPA 200.8	430521		
70391830020	HS-20	EPA 200.8	430521		
70391830021	HS-21	EPA 200.8	430521		
70391830022	HS-22	EPA 200.8	430521		
70391830023	HS-23	EPA 200.8	430521		
70391830024	HS-24	EPA 200.8	430521		
70391830025	HS-25	EPA 200.8	430521		
70391830026	HS-26	EPA 200.8	430521		
70391830027	HS-27	EPA 200.8	430521		
70391830028	HS-28	EPA 200.8	430521		
70391830029	HS-29	EPA 200.8	430521		
70391830030	HS-30	EPA 200.8	430521		
70391830031	HS-31	EPA 200.8	430521		
70391830032	HS-32	EPA 200.8	430521		
70391830033	HS-33	EPA 200.8	430521		
70391830034	HS-34	EPA 200.8	430523		
70391830035	HS-35	EPA 200.8	430523		
70391830036	HS-36	EPA 200.8	430523		
70391830037	HS-37	EPA 200.8	430523		
70391830038	HS-38	EPA 200.8	430523		
70391830039	HS-39	EPA 200.8	430523		
70391830040	HS-40	EPA 200.8	430523		
70391830041	HS-41	EPA 200.8	430523		
70391830042	HS-42	EPA 200.8	430523		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name:	Intertek-PSI	Contact/Report To:	William Kotas
Street Address:	17 British American Blvd, Latham, NY 12210	Phone #:	(518) 377-9841
Customer Project #:		E-Mail:	william.kotas@intertek.com
Project Name:	Burnt Hills Balliston Lake CSD	Cc E-Mail:	
Site Collection Info/Facility ID (as applicable):		Invoice To:	PSI Latham Accounts Payable
		Invoice E-Mail:	LathamAR@intertek.com
		Purchase Order # (if applicable):	
		Quote #:	CR-BOCES
Time Zone Collected:	[] AK [] PT [] MT [] CT [X] ET	County / State origin of sample(s):	New York
Data Deliverables:		Regulatory Program (DW, RCRA, etc.) as applicable:	NY Lead in School DW
[] Level II	[] Level III		
[] EQUIS			
[] Other			
		Rush (Pre-approval required):	DW PWSID # or WW Permit # as applicable:
		[] 2 Day [] 3 day [] 5 day [] Other	
		Date Results Reminested:	
		Standard 10 business day	
			Field Filtered (if applicable): [] Yes [] No
			Analysis:

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End		Res. CL2	Number & Type of Containers	
			(or Composite Start)	Time	Date	Time		Plastic	Glass
	DW	G							1
HS-01			11/13/25	4:51					
HS-02				4:53					
HS-03				4:54					
HS-04				4:55					
HS-05				4:56					
HS-06				4:56					
HS-07				5:00					
HS-08				5:02					
HS-09				5:03					

Customer Remarks / Special Conditions / Possible Hazards: Lead	Collected By: Printed Name: William A. Kotus Signature:
Retinquished by/Company: Signature: <i>W. Kotus</i>	Received by/Company: Signature: <i>W. Kotus</i>
Retinquished by/Company: Signature: <i>pac</i>	Received by/Company: Signature: <i>W. Kotus</i>
Retinquished by/Company: Signature: <i>W. Kotus</i>	Received by/Company: Signature: <i>W. Kotus</i>

Submitting a sample via this chain of custody constitutes acknowledgement and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/>

Specify Container Size **		Identify Container: Preservative Type***		Analysis Requested		Preservation non-conformance identified for sample		Sample Comment	
** Container Size	(1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other	*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod Thiosulfate, (9) Ascorbic Acid, (10) Mech, (11) Other					Proj. Mgr: Lori Beyer	AcctNum / Client ID:	
							Table #:		
							Profile / Template: 10367		
							Prelog / Bottle Ord. ID:		
							Lab Use Only		

[illegible]

Additional Instructions from Page*:		Thermometer ID:		Correction Factor (°C):		Obs. Temp. (°C)		Corrected Temp. (°C)	
		Date/Time: 11/14/25		Tracking Number: 1130					
		Date/Time: 11/15/25		Delivered by: [] In-Person [] Courier					
		Date/Time: 7:57		[] FedEx [] UPS [] Other					
		Date/Time:		Page:				of	

space-terms-and-conditions/
ENV-FRM-CORQ-0019_v01_082123 ©

Pace® Location Requested (City/State): Pace Analytical Long Island NY 575 Broad Hollow Rd, Melville, NY 11747	Company Name: Intertek-PSI	Street Address: 17 Br-Rish American Blvd, Latham, NY 12120	Contact/Report To: William Kotas (518) 377-9841 E-Mail: william.kotas@intertek.com Cc E-Mail:
Customer Project #: Burnt Hills Ballston Lake CSD	Project Name: Burnt Hills Ballston Lake CSD	Invoice To: PSI Latham Accounts Payable LathamAR@intertek.com	Invoice To: PSI Latham Accounts Payable LathamAR@intertek.com
Site Collection Info/Facility ID (as applicable):	Purchase Order # (if applicable):	Quote #:	CR-BOCES
Time Zone Collected: [] AK [] PT [] MT [] CT [] ET	Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW	County / State origin of sample(s): New York	
Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other _____	Rush (Pre-approval required): [] 1 Day [] 3 day [] 5 day [] Other _____ Date Results Requested: Standard 10 business day	Field Filtered (if applicable): [] Yes [] No Analysis: _____	DW PWSID # or WW Permit # as applicable: _____
* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Blossay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk	Matrix *	Collected (or Composite Start) Date Time	Composite End Date Time
Customer Sample ID	Comp / Grab	Res. CL2	Number & Type of Containers Plastic Glass
H5-10	G		1
H5-11	G	11/13/25 5:06	
H5-12	G	5:09	
H5-13	G	5:10	
H5-14	G	5:12	
H5-15	G	5:14	
H5-16	G	5:17	
H5-17	G	5:18	
H5-18	G	5:24	
Additional Instructions from Pace®:	Collected By: Printed Name: William A. Kotas Signature:	# Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp (°C): Corrected Temp (°C)	Tracking Number: Date/Time: 11/11/25 11:30 Delivered by: [] In-Person [] Courier [] FedEx [] UPS [] Other Date/Time: 11/15/25 7:37 Page: of

[illegible]

Chain-Of-Custody Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/LogIn Label Here

Scan QR Code for instructions

Company Name: Intertek-PSI

Street Address: 17 British American Blvd, Latham, NY 12110

Customer Project #:

Project Name: Burnt Hills Ballston Lake CSD

Site Collection Info/Facility ID (as applicable):

Contact/Report To: William Kotas

Phone #: (518) 377-9841

E-Mail: william.kotas@intertek.com

Cc E-Mail:

Invoice To: PSI Latham Accounts Payable

Invoice E-Mail: LathamAR@intertek.com

Purchase Order # (if applicable):

Quote #: CR-BOCES

County / State origin of sample: New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required): DW PWSID # or WW Permit # as applicable:

Date Results Requested: Standard 10 business day

Field Filtered (if applicable): ☐ Yes ☐ No

Analysis:

Matrix *: DW

Comp / Grab: G

Customer Sample ID:

Time Zone Collected: ☐ AK ☐ PT ☐ MT ☐ CT ☐ ET

Data Deliverables:

☐ Level II ☐ Level III ☐ Level IV

☐ EQUIS

☐ Other

*** Matrix Codes (Insert in Matrix box below):** Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Additional Instructions from Pace®:

Coolers: _____

Thermometer ID: _____

Correction Factor (°C): _____

Obs. Temp (°C): _____

Corrected Temp (°C): _____

Tracking Number:

Delivered by: ☐ In-Person ☐ Courier

☐ FedEx ☐ UPS ☐ Other

Page: _____ of _____

Received by/Company (Signature):

Date/Time: 11/14/25 11:30

Received by/Company (Signature):

Date/Time: 11/14/25 12:30

Received by/Company (Signature):

Date/Time: 11/15/25 8:37

Received by/Company (Signature):

Date/Time: 11/15/25 12:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Additional Instructions from Pace®:

Coolers: _____

Thermometer ID: _____

Correction Factor (°C): _____

Obs. Temp (°C): _____

Corrected Temp (°C): _____

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Collected By: William A. Kotas

Signature:

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

Received by/Company (Signature):

Date/Time: 11/15/25 11:30

[illegible]

Multiday Project

Add SCLOGFD to first sample for field charge

Container Codes

	Matrix
WT	Water
SL	Solid
NAL	Non-aqueous Liquid
OL	Oil
WP	Wipe
DW	Drinking Water

¹ Can also be a BP4N

	SOC
VG9T	40mL Na Thio amber vial
DG9A	40mL Acetic acid/ malic Acid vials
DG9Y	Citrate/Na Thiosulfate 40mL
DG9T	Na Thiosulfate 60mL vial
DG8M	MonoChloroAcetic/Na Thio 60mL
AG3U	250mL unresps amber glass
AG3T	Na Thiosulfate 250mL bottle
pp1B	Na Thiosulfate Amber bottle
AG1T	Na Thiosulfate 1L Amber
AG1A	525 x Chemical Bleach

Sender Initials

Additional Comments

Spot CO₂

W0#: 70391829

Due Date: 12/03/25

em: LAB

CLIENT: INTER-LATHAM

WO#: 70391830

PM: LAB Due Date: 12/03/25
CLIENT: INTER-LATHAM

Client Name: Inter - Latham

Project #

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☒ Ziploc ☐ None ☐ Other Type of Ice: ☒ Wet ☐ Blue ☐ None

Thermometer Used: TH211 Correction Factor: 0.1 ☐ Samples on ice, cooling process has begun

Cooler Temperature(°C): 17.2 Cooler Temperature Corrected(°C): 17.3 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☐ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☒ No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 11/18/25

	COMMENTS:
Chain of Custody Present: ☒ Yes ☐ No	1.
Chain of Custody Filled Out: ☒ Yes ☐ No	2.
Chain of Custody Relinquished: ☒ Yes ☐ No	3.
Sampler Name & Signature on COC: ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time: ☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr): ☐ Yes ☒ No	6.
Rush Turn Around Time Requested: ☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) ☒ Yes ☐ No	8.
Correct Containers Used: ☒ Yes ☐ No	9.
-Pace Containers Used: ☒ Yes ☐ No	10.
Containers Intact: ☒ Yes ☐ No	11.
Filtered volume received for Dissolved tests ☐ Yes ☐ No ☒ N/A	Note: if sediment is visible in the dissolved container.
Sample Labels match COC: ☒ Yes ☐ No	12.
-Includes date/time/ID/Analysis Matrix: <u>SL</u> <u>WT</u> ☐ OIL ☐ OTHER	

Date and Initials of person checking preservation: 11/18/25

All containers needing preservation have been pH paper Lot # <u>210526</u> ☒ Yes ☐ No ☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, ☒ Yes ☐ No ☐ N/A NAOH>12 Cyanide)	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Per Method, VOA pH is checked after analysis	14.
Samples checked for dechlorination: ☐ Yes ☐ No ☒ N/A	Positive for Res. Chlorine? Y N
KI starch test strips Lot #	15.
Residual chlorine strips Lot #	Positive for Sulfide? Y N
SM 4500 CN samples checked for sulf ☐ Yes ☐ No ☒ N/A	16.
Lead Acetate Strips Lot #	17.
Headspace in ALK Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	
Headspace in VOA Vials (>6mm): ☐ Yes ☐ No ☒ N/A	
Trip Blank Present: ☐ Yes ☐ No ☒ N/A	
Trip Blank Custody Seals Present ☐ Yes ☐ No ☒ N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.